

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7256-1468:103

Page 1 of 1

CATEGORY: Single/Multiple Station Smoke Detector-Ionization

LISTEE: Nighthawk Systems, 4980 Centennial Blvd., Colorado Springs, CO 80919
Contact: *Larry Ratzlaff (847) 742-5165 Ext 1002

DESIGN: Models 0914, 0915, 0916 and 0918 single station, battery operated, ionization smoke detectors. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 9 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as single station ionization smoke detectors.
These models are non-temporal and are intended for use in occupancies that do not require total evacuation but perhaps relocation or notification. If a distinctive temporal code pattern fire alarm signal (for total evacuation) in accordance with NFPA 72, 1996 Edition is required, do not use these units. Refer to other listings which provide temporal devices.

NOTE: The ionization type detectors are generally more effective at detecting fast, flaming fires which consume combustible materials rapidly and spread quickly. Sources of these fires may include paper burning in a waste container or a grease fire in the kitchen. The photoelectric type detectors are generally more effective at detecting slow, smoldering fires which smolder for hours before bursting into flame. Sources of these fires may include cigarettes burning in couches or bedding.

XLF: 7256-0630:111

*Rev. 06-21-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 21, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager